


White Horse Springs Water District System Report – January 12th, 2023

**Monthly metered domestic water usage from the Badger Beacon AMA software [2020 - 2022]**




**2016 - 5.6 Mgals; 2017 – 5.7 Mgals; 2018 - 5.3 Mgals, 2019 - 4.2 Mgals**

**2020 - 5.3 Mgals, 2021 - 4.74 Mgals, 2022 - 4.97 Mgals**

**Yearly metered domestic water usage from the Badger Beacon AMA software [2016 - 2022]**

Yearly metered usages in Mgals [w/o Stewart Irr tap usage until June of 2022]



**Cont' 2021 WHSWD Capital Projects**

- Tank Mixer completed in 2022
- Back-up power generator: final hand-off from Contractor scheduled for Jan 19th, 2 pm

**2022 July 29th Sanitary Survey**

- the BPCCC program, specifically the new interpretation of the regulations by the State Inspector and the related work/administration; BFPD testing ratio of 100% achieved by the end of 2022

Roy Saba

A handwritten signature in black ink that reads "Roy SABA". The signature is enclosed in a thin red rectangular border.

Operator in Responsible Charge [ORC] of the White Horse Springs Domestic Water System

Certified Water System Professional #13601  
Individual Member of the Colorado Rural Water  
Association